

August 30, 2017

Dear Sir:

Attached is Addendum No. 1 dated August 30, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1341, Municipality of Emerson-Franklin Booster Pumping Station and Meter Station. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1 dated August 30, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1341, Municipality of Emerson-Franklin Booster Pumping Station and Meter Station.

Yours truly,

Company

Per

THE MANITOBA WATER SERVICES BOARD

CONTRACT NO. M.W.S.B. 1341

**MUNICIPALITY OF EMERSON-FRANKLIN
BOOSTER PUMPING STATION AND METER STATION**

ADDENDUM NO. 1

To the tender documents for:

August 30, 2017

1) PRECEDENCE

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

2) SCOPE

The purpose of this addendum is to amend the following sections of the Tender Documents:

1. Section 01001 Special Provisions, Clause 1.02 “DESCRIPTION OF WORKS” revise as follows:

Add point to Clause 1.02:

- **“Supply and install new chemical dosing pump, chlorine injection point, spill containment pallet and controls to existing electrical panel. Provide and install all connections, conduit, wiring, breakers and switches necessary to provide a complete service.”**

2. Section 01001 SPECIAL PROVISIONS, add the following clauses:

2.36 CHEMICAL DOSING PUMP	Chemical dosing pumps shall be programmable with auto-degassing head and calibration column. Chemical dosing pumps shall be Prominent Gamma/X or Grundfos DDA 7.5 or approved equal complete with PE chemical line to dosing point appropriately secured with foot valve. One (1) pump to be supplied capable of feeding a range of at least 0.2 – 2.1 L/hr c/w mounting stands, backpressure valves and injection valves.
2.37 SPILL CONTAINMENT	Spill containment pallet shall be PE, 2-drum with minimum 200 L capacity and grating c/w bulkhead drain.

3. Section 01150 Measurement and Payment, revise the following Clauses:

1.05 MECHANICAL WORKS	<p>1. METHOD OF MEASUREMENT – No measurement will be made for mechanical works.</p> <p>2. BASIS OF PAYMENT – The supply and installation of mechanical works shall be paid for at the Lump Sum Contract Price for each “Mechanical Works”. This price shall include the supply and installation of piping, fittings, gauges, valves, strainers, water meter, booster pumps, pressure tank, pipe supports, dosing pump, chemical spill pallet, chlorine injection point, fan and louver, stainless steel bolts, washers and nuts, floor drain and sump, manuals commissioning and training and for those operations incidental to the work for which no price or provisions for payment are included in the Contract.</p>
--------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

4. Revision on Drawing 4 of 5 Booster Pumping Station Mechanical & Electrical:

“Remove 50 Butterfly Valve Gear Operated on Combination Air/Vacuum Valve and replace with 50 Ball Valve as per Listing of Approved Products of the MWSB Standard Construction Specifications 2013.”

END OF ADDENDUM