

August 17, 2017

Dear Sir:

Attached is Addendum No. 1 dated August 17, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1369, Southwest Regional Water Co-Op Water Well Mechanization and Booster Stations. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

**\*  
ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS  
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle  
Construction Manager

---

The Manitoba Water Services Board  
Unit #1A - 2010 Currie Blvd.  
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1 dated August 17, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1369, Southwest Regional Water Co-Op Water Well Mechanization and Booster Pumping Stations.

Yours truly,

---

Company

---

Per

**THE MANITOBA WATER SERVICES BOARD**

**CONTRACT NO. M.W.S.B. 1369**

**Southwest Regional Water Co-Op Water Well Mechanization  
And Booster Pumping Stations**

**ADDENDUM NO. 1**

To the tender documents for:

August 17, 2017

1) PRECEDENCE

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

2) SCOPE

The purpose of this addendum is to amend the following sections of the Tender Documents:

PLANS Pg. 2 of 5 BOOSTER STATION NO. 1

Delete Note shown on plan and replace with the following Note:

All interior piping before and after pump discharge shall be stainless steel.

END OF ADDENDUM