

October 4, 2017

Dear Sir:

Attached is Addendum No. 2 dated October 4, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1391, Town of Niverville, Contract 2: Well Mechanization. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 2 dated October 4, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1391, Town of Niverville, Contract 2: Well Mechanization.

Yours truly,

Company

Per

THE MANITOBA WATER SERVICES BOARD

CONTRACT NO. M.W.S.B. 1391

TOWN OF NIVERVILLE

CONTRACT 2: WELL MECHANIZATION

ADDENDUM NO. 2

To the tender documents for the Town of Niverville, Contract 2: Well Mechanization

October 4, 2017

PRECEDENCE

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

SCOPE

The purpose of this addendum is to amend the following sections of the Tender Documents:

1.1 DRAWING 4963-01-E-102

- .1 Clarification of power to South Well from Control Building:
 - .1 As an alternative installation to conduit and conductors, the power supply to the south well can be installed via trenching underground cable.
 - .1 Cable shall be Teck 90, installed as one continuous cable without splices.
 - .2 Bury depth shall be minimum 900mm.
 - .3 Cable installation shall include polyethylene underground warning tape.
 - .4 Installation shall be complete with ground restoration, and **two-year warranty** on restored trench for settlement, and vegetation growth.
 - .5 All road crossings shall be trenchless. No open cut, disturbances, or interruptions to Willow Ridge or Crown Valley.

1.2 TECK 90 CABLE

- .1 Cable: to CAN/CSA-C22.2 No. 131.
- .2 Conductors:
 - .1 Grounding conductor: copper, size as indicated.
 - .2 Circuit conductors: copper, size as indicated.
- .3 Insulation:

- .1 Ethylene propylene rubber EP.
- .2 Chemically cross-linked thermosetting polyethylene rated type RW90, 1000 V for 600 V systems, minimum 600 V for 208 V (or lower) systems.
- .4 Inner jacket: polyvinyl chloride material.
- .5 Armour: flat interlocking aluminum.
- .6 Overall covering: thermoplastic polyvinyl chloride, compliant to applicable Building Code classification for this project, and underground installation.
- .7 Teck connectors shall be Thomas and Betts Star Teck ST.
- .8 Cables shall be FT4 or FT6 rated and marked.

END OF ADDENDUM #2