

June 20, 2017

Dear Sir:

Attached is Addendum No. 2 dated June 20, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1392, City of Selkirk 12 MLD Wastewater Treatment Plant Membrane Bioreactor System Supply. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1392 dated June 20, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1392, City of Selkirk 12 MLD Wastewater Treatment Plant Membrane Bioreactor System Supply.

Yours truly,

Company

Per

THE MANITOBA WATER SERVICES BOARD

CONTRACT NO. M.W.S.B. 1392

**City of Selkirk
12 MLD Wastewater Treatment Plant
Membrane Bioreactor System Supply
ADDENDUM NO. 2**

To the tender documents for:

June 20, 2017

1) PRECEDENCE

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

2) SCOPE

The purpose of this addendum is to amend the following sections of the Tender Documents:

1. Revise clause 6.1 in General Conditions for Supply Contracts to read as follows:

6.1 The equipment performance shall remain at the risk and responsibility of the Supplier up until delivery to the site at which time the Prime Contractor shall be responsible until the date of Substantial Performance.

2. Revise clause 2.9.3.8 in Section 11455-Positive Displacement Blowers to read as follows:

.8 Provide shaft grounding ring for protection of bearing current flow in all VFD applications over 100 hp. Grounding ring shall be AEGIS SGR by Electro Static Technology.

END OF ADDENDUM