

November 9, 2017

Dear Sir:

Attached is Addendum No. 01 dated July 10, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1403, Great Falls Water Treatment Plant. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 01 dated November 9, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1403, Great Falls Water Treatment Plant.

Yours truly,

Company

Per

THIS PAGE INTENTIONALLY LEFT BLANK

THE MANITOBA WATER SERVICES BOARD

CONTRACT NO. M.W.S.B. 1403

R.M. OF ALEXANDER GREAT FALLS WATER TREATMENT PLANT

ADDENDUM NO. 1

Nov 9, 2017

1) PRECEDENCE

This addendum has been issued prior to the receipt of tenders and forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

2) SCOPE

The purpose of this addendum is to amend the following items of the Tender Documents:

.1 **SPECIFICATIONS**

.1 Section 23 82 39 – Unit Heaters

.1 This section to be deleted in its entirety.

.2 **DRAWINGS**

.1 E-102 – Lighting Plan

.4 Include the following luminaire schedule:

LUMINAIRE SCHEDULE							
TYPE	DESCRIPTION	CATALOGUE NO.	COLOR TEMPERATURE	LAMPS	MOUNTING	VOLTS	REMARKS
A	LED VAPOUR TIGHT OPEN CEILING TYPE 1x4	LITHONIA - VP4-LA3A-8/40K OR METALUX 4VT2-LD4-8-DR-W-UNV-L840-CD1-WL-U	4000 K	LED	SUSPENDE	120	1, 3
B	RECESSED DRYWALL LED TYPE 1x4	LITHONIA - BLT4-MG-40L-SDP-LP840 OR METALUX - 14CZ-LD5-44-UNV-L840-CD1-U	4000 K	LED	RECESSED	120	1, 2
C	RECESSED T-BAR LED 2x4	LITHONIA - 2BLT4R-40L-SDSM-LP840 OR METALUX 24CZ-LD5-60SE-UNV-L840-CD1-U	4000 K	LED	RECESSED	120	1
D	LED EXTERIOR WALL PACK	LITHONIA-TWR1 LED 1 50K MVOLT OR LUMARK - XTOR8BRL-W-PC1	4000 K	LED	WALL	120	1
E	LED OPEN CELING TYPE 1x4	LITHONIA - LBL4 40L EZ1 LP840 OR METALUX 4WNLED-LD4-50SL-F-UNV-L840-CD1-U	4000 K	LED	SUSPENDE	120	1
R	ALARM BEACON, WEATHERPROOF	LP3P OR EQUIVALENT		SOLID STATE		120	

NOTES:

1. ELECTRICAL CONTRACTOR TO COORDINATE ON SITE WITH OTHER TRADES FOR LIGHTING LUMINAIRE'S MOUNTING LOCATION.
2. PROVIDE DRYWALL FRAME KIT.
3. LUMINAIRE'S IN PROCESS AREA ARE CONTROLLED BY SUSPENDE OCCUPANCY SENSOR (MODEL: CM-PIR-6-LT BY ACUIY CONTROLS) C/W PP20 POWER PACK.

EMERGENCY BATTERY SCHEDULE						
TYPE	MANUFACTURER	DESCRIPTION	CATALOGUE NO.	LAMPS	VOLTS	REMARKS
BB-1	EMERGI LITE OR EQUIVALENT LUMACELL	250 W EMERGENCY BATTERY PACK UNIT C/W 2 x 6 WATTS LED INDUSTRIAL GRADE, 120VAC POWER SUPPLY AND 12VDC POWER TO REMOTE HEADS.	12ESL250UN2LJ	LED	120	WALL MOUNTED AT 2590MM A.F.F.
ER-1	EMERGI LITE OR EQUIVALENT LUMACELL	TWO HEADS LED 12-6W, CONNECT TO BATTERY PACK INDICATED. FIXTURE SHALL BE MOUNTED TIGHT TO U/S ROOF DECK. COORDINATE MOUNTING LOCATION WITH MECHANICAL/STRUCTURAL AND SIGNAGE.	EF9-D-M-LJ,	LED	12V	
ER-2	EMERGI LITE OR EQUIVALENT LUMACELL	TWO HEADS LED 12V-6W LAMP. CONNECT TO BATTERY BANK INDICATED.	EF26D-MR16-12-LJ	LED	12V	
ER-3	EMERGI LITE OR EQUIVALENT LUMACELL	DOUBLE LAMP CONFIGURATIONS AND INCLUDE A UV RESISTANT CLEAT HEAVY DUTY RESISTANT POLYCARBONATE LIGHT COVER.	EF40PDMLJ	LED	120V	
EX-1	EMERGI LITE OR EQUIVALENT LUMACELL	EXIT SIGN, RUNNING MAN GREEN PICTOGRAM RATED NEMA 4X SINGLE FACE, WHITE, 120VAC	LS1S	LED	120V	

NOTES: ALL REMOTE HEADS WIRING SHALL BE MINIMUM #10 AWG CU AND LARGER AS REQUIRED FOR ≤ 5% VOLTAGE DROP.

END OF ADDENDUM