

November 15, 2017

Dear Sir:

Attached is Addendum No. 1 dated November 15, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1406, RM of Portage la Prairie Water Pipeline Replacement 2017. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1 dated November 15, 2017 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1406, RM of Portage la Prairie Water Pipeline Replacement 2017.

Yours truly,

Company

Per

THE MANITOBA WATER SERVICES BOARD

CONTRACT NO. M.W.S.B. 1406

RM of Portage la Prairie Water Pipeline Replacement 2017

ADDENDUM NO. 1

To the tender documents for:

November 15, 2017

PRECEDENCE

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

SCOPE

The purpose of this addendum is to amend the following sections of the Tender Documents:

1) REVISED SECTION TITLE

- a) Replace section title labelled 01150 (MWSB #1406) Measurement & Payment (14 pages) with 01001 (MWSB #1406) Special Provisions.

2) SECTION 01001 – SPECIAL PROVISIONS

- a) Add clause to **Item 2.17 Water Meter (meter chamber)**
 - i) Water meter shall be suitable for submerged pit applications. Meter shall be complete with remote meter read (MXU) that is compatible with Sensus AMR meter read system. The remote reader shall be mounted below the hatch of the meter chamber.
- b) Add clause to **Item 2.14 Butterfly Valves (meter chamber)**
 - i) All butterfly valves shall have epoxy coated exterior coating and shall be suitable for submerged applications.

3) DRAWINGS – SHEET #3 OF 4

- a) Plan indicates (2) 200x200x150mm tee on the connection to the existing 200mm existing pipeline and (2) 150mm gate valves, the connection shall be (2) 200x150mm tapping sleeves c/w 150mm gate valves as indicated in the Special Provisions and Measurement and Payment.

END OF ADDENDUM