

March 6, 2018

Dear Sir:

Attached is Addendum No. 4 dated March 6, 2018 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1414, Town of Snow Lake Phase 2 Water and Sewer Infrastructure Renewal. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 4 dated March 6, 2018 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1414, Town of Snow Lake Phase 2 Water and Sewer Infrastructure Renewal.

Yours truly,

Company

Per

THE MANITOBA WATER SERVICES BOARD

CONTRACT NO. M.W.S.B. 1414

**The Town of Snow Lake
Phase 2 Water and Sewer Infrastructure Renewal**

ADDENDUM NO. 4

To the tender documents for:

Date: March 6, 2018

1) PRECEDENCE

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

2) SCOPE

The purpose of this addendum is to amend the following sections of the Tender Documents:

.1 Replace the following clauses in Special Provisions Section 01001:

30. Pipe Gaskets

- .1 Watermain gaskets to be as described within City of Steinbach TS 5300 Clause 3.3.
- .2 Sewermain gaskets to be as described within City of Steinbach TS 5400 Clause 3.3.

.2 Add the following clauses in Special Provisions Section 01001:

31. Temporary Watermain By-Pass

- .1 Work shall be sequenced and prioritized to minimize the number of water system shutdowns required. Coordinate shutdown windows with other work where possible.
- .2 Sequence installation of mains to minimize the amount of time the by-pass is in use.

END OF ADDENDUM