

April 9, 2018

Dear Sir:

Attached is Addendum No. 1 dated April 9, 2018 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1420, Town of Neepawa, PTH 5 Watermain Extensions. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

**\*  
ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS  
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle  
Construction Manager

---

The Manitoba Water Services Board  
Unit #1A - 2010 Currie Blvd.  
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1 dated April 9, 2018 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1420, Town of Neepawa, PTH 5 Watermain Extensions.

Yours truly,

---

Company

---

Per

**THE MANITOBA WATER SERVICES BOARD**

**CONTRACT NO. M.W.S.B. 1420**

**TOWN OF NEEPAWA  
PTH 5 WATERMAIN EXTENSIONS**

**ADDENDUM NO. 1**

To the tender documents for the Town of Neepawa, PTH 5 Watermain Extensions

April 9, 2018

**PRECEDENCE**

This addendum forms an integral part of the specifications describing all aspects of the work and is to be read in conjunction therewith.

**SCOPE**

The purpose of this addendum is to amend the following sections of the Tender Documents:

**1.1 REVISED FORM NO. MWSB 3B**

- .1 Use the revised Schedule of Quantities and Prices included with this addendum.

**1.2 REVISED COMPLETION DATE**

- .1 Substantial performance shall be achieved:
  - .1 On or before September 28, 2018 and within **40** working days.

**1.3 RAILWAY CROSSING**

- .1 Railway crossing **MUST** be completed using the installation method shown in the drawing and described in the specifications. Contractor may formally propose an alternate method for review and approval from the Design Engineer, Geotechnical Engineer and Railway.
  - .1 Note that alternate methods may result in changes to the design depth and add the requirement of an engineering shoring/sheet pile system.
- .2 All costs associated with the additional reviews and/or construction requirements shall be borne by the Contractor.

#### **1.4 PIPE MATERIAL**

- .1 C900 PVC bell and spigot piping shall be considered an acceptable equivalent to HDPE DR17 for all pipeline installation.
  - .1 Exception: Rail crossing carrier pipe **must** remain HDPE DR17.
  - .2 All valves and hydrants must be mechanically restrained.

#### **1.5 FIRE HYDRANTS**

- .1 Standard of acceptance: Mueller Super Centurion, no equals.

#### **1.6 GATE VALVE**

- .1 Valve Box Assembly:
  - .1 Standard of Acceptance: WD Valve Boxes, model WD46, no equals.
- .2 Valve Spindle:
  - .1 Standard of Acceptance: WD Valve Boxes, model VBS-1, no equals.

#### **1.7 CURB STOP**

- .1 Service Box and Spindle:
  - .1 Standard of Acceptance: WD Industrial, SB 31 XL and WD120, no equals.

#### **1.8 DRAWING 4017-00-C102**

- .1 Plan 4, revise stub at Sta 1+220.713 to “Connect to Existing 200 mm Ø Watermain With New 300x200 Reducer and 200 mm Ø Gate Valve”.

**END OF ADDENDUM #1**

SCHEDULE OF PRICES - PROJECT NO. MWSB 1420

Item No.	Description	Approx. Quantity	Unit	Unit Price \$0.00	Total Price \$0.00
<b>1.0</b>	<b><u>WATERMAIN EXTENSION</u></b>				
<b>1.1</b>	<b><u>Pressure Pipeline</u></b>				
1.1.1	300 mm diameter HDPE DR17 Pipe	1465	Lin. m.		
1.1.2	250 mm diameter HDPE DR17 Pipe	510	Lin. m.		
1.1.3	150 mm diameter HDPE DR17 Pipe	3	Lin. m.		
1.1.4	100 mm diameter HDPE DR17 Pipe	195	Lin. m.		
1.1.5	38 mm Service Pipe	315	Lin. m.		
<b>1.2</b>	<b><u>Crossings (Encased)</u></b>				
1.2.1	300 mm PTH 5 Crossing	2	Each		
1.2.2	250 mm PTH 5 Crossing	1	Each		
1.2.3	38 mm PTH 5 Crossing	3	Each		
1.2.4	300 mm Hurrell Road Crossing	1	Each		
1.2.5	300 mm Railway Crossing	1	Each		
<b>1.3</b>	<b><u>Gate Valve</u></b>				
1.3.1	300 mm	4	Each		
1.3.2	250 mm	1	Each		
1.3.3	150 mm	1	Each		
1.3.4	100 mm	1	Each		
<b>1.4</b>	<b><u>Flushout Assemblies</u></b>				
1.4.1	100 mm End of Line	1	Each		
<b>1.5</b>	<b><u>Water Service Connections</u></b>				
1.5.1	38 mm Corporation & Curb Stop	18	Each		
<b>1.6</b>	<b><u>Fire Hydrant Assemblies</u></b>				
1.6.1	Hydrant Assembly	17	Each		
<b>1.7</b>	<b><u>Connection to Existing</u></b>				
1.7.1	Commerce Street c/w (1) 200 mm Gate Valve	1	Each		
1.7.2	Pool Street c/w (2) 300 mm Gate Valves	1	Each		
1.7.3	PTH 5 @ Pool Street c/w (2) 300 mm Gate Valves & (1) 200 mm Gate Valve	1	Each		
1.7.4	Hurrell Road	1	Each		

	<b>EXTRA WORK ALLOWANCE</b>		\$75,000.00
		<b>Sub-total</b>	
	<b>*PST must be included in unit prices.</b>	<b>GST (5%)</b>	
		<b>TOTAL TENDER PRICE</b>	

\_\_\_\_\_  
Name of Bidder