

RM OF TACHÉ – LANDMARK WATERMAIN UPGRADES

MWSB #1421

734-1715360300-TS-C0004-00

ADDENDUM No. 3

Please note the changes, corrections, additions, deletions, information, and/or instructions in connection with the work to be done under this Contract, and submit prices and be governed accordingly. This Addendum shall be incorporated with the specifications and shall form part of the Contract Documents.

Please acknowledge receipt of this Addendum in the Bid Form.

FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE BID FORM MAY RENDER THE BID INFORMAL.

Date _____ Signature _____

ADDENDUM NUMBER: 3
DATE OF ISSUE: May 22, 2018
ISSUED BY: Trevor Christiansen, P.Eng.
Telephone: 204.954.6800

This Addendum forms part of the Contract Documents and amends the original Specifications May 4, 2018.

This Addendum consists of 2 pages, including the signature page.

Ensure that all parties submitting bids are aware of all items included in this Addendum.

ITEM 1 SECTION 331100 PRESSURE PIPE

2.3 GATE VALVES AND VALVE BOXES shall read:

- .1 Gate valves shall conform to AWWA C509 latest revision and ULC & FM listed. Resilient seat, rated at 1000 kPa (water) working pressure service. Gate valves will be approved products as per Manitoba Water Services Board (May 2015) Appendix Listing of Approved Products.
 - .1 Muller Resilient Wedge Gate Valve (AWWA C509) AT2360 Series (Flanged) or approved equal.
 - .2 All gate valves shall be of flanged connection.

ITEM 2 SECTION 010001 SPECIAL PROVISIONS

1.12 MATERIAL AND EQUIPMENT

Add clause 1.12.5 Hydrants

- 1. The Town of Landmark existing hydrants are “Canada Valve Century” including thread requirements, spare parts and tools for maintenance. The Contractor shall use Mueller “Canada Valve Century” for hydrant installation to match existing Town of Landmark hydrants. There will be no alternatives considered.

END OF ADDENDUM No. 3