

August 13, 2018

Dear Sir:

Attached is Addendum No. 1 dated August 13, 2018 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1445, Municipality of Westlake-Gladstone, Gladstone Water and Sewer Renewal. Please verify receipt of this Addendum for our records by fax to (204) 726-6290.

ACKNOWLEDGEMENT OF RECEIPT OF ALL ADDENDUMS
MUST BE INCLUDED IN THE TENDER SUBMISSION.**

Failure to include acknowledgement shall cause the tender to be rejected. If Tender is submitted before Addendum is issued, the Board will accept a faxed acknowledgement prior to the tender closing.

Yours truly,

R. Lytle
Construction Manager

The Manitoba Water Services Board
Unit #1A - 2010 Currie Blvd.
Brandon, MB R7B 4E7

Dear Sir:

We have received Addendum No. 1 dated August 13, 2018 to the Specifications for The Manitoba Water Services Board Contract No. M.W.S.B. 1445, Municipality of Westlake-Gladstone, Gladstone Water and Sewer Renewal.

Yours truly,

Company

Per



From: Matt Fisher, P.Eng.

To: Whom It May Concern

The following changes to the Tender Documents are effective immediately and will form part of the Tender Documents. Please insert the Addendum to the inside cover of the Specifications.

This Addendum #01 is to amend the following sections of the Tender Document:

1. Revise MWSB 3A
 - .1 Submission Deadline extended to August 24, 2018.
2. Section 01001 –Section 7.16.2 to be replaced with:
 - .1 Conform to AWWA C502. Standard for dry-barrel fire hydrants and be approved by the Underwriters Laboratory of Canada. Design for working pressure of 1,000 kPa with two 65 mm threaded hose outlets, one 112 mm (4 1/2") pumper nozzle, and 150 mm connection at main. Hydrants to open counter clockwise, threads to local standard. Depth of bury as shown on plans.

Please sign below to signify that you have reviewed the attachment and ensure that the attachment is included with your tender document.

BIDDER'S SIGNATURE